

Pure Chlorine Unit summer stop

If the chlorine production section is to be made free of chlorine, it is advisable to refresh the membrane cell. This means that the spent salt (anolyte), which can be quite acidic, is removed and replaced by new brine. The latter is much more user-friendly. To do this, everything in the installation must be switched on

- In the menu, press OPERATION



- Enter the password (4444)

- Press OK

- Press OPERATION again



- Turn Off PRODUCTIE.

- Perform 5 x anode refresh under manual control (this makes the system almost chlorine-free)

- Turn the Venturi pump(s) OFF

- Turn the fan OFF

- Turn the MAIN SWITCH OFF*.

- Turn off the water tap

- Close the shut-off valve of the dosing pipe

- Close the valves before and after the venturi

- Close the suction and discharge valve of the Venturi pump



*(During maintenance work, it is mandatory to switch off the main switch)

If there is no release to dose chlorine, no chlorine is produced. The Pure Chlorine unit is then on stand-by. Another option is to switch off the unit completely at the main switch. In both cases, start-up must be done via KaRo. During start-up the necessary maintenance is also carried out.

